



NOTES:

1. ALL LIGHTING CONTACTORS SHALL HAVE 120 VOLT COILS WITH H-O-A SWITCHES.

NOTES:

1. LIGHTING CONTROLS SHALL BE VIA LIGHTING CONTROL PANEL EQUAL TO LITHONIA SWITCHPAK MODEL #SPAK-85-120/277-LA APS QL WITH TWO OVERRIDE SWITCHES MODEL #LVR5-1G-6SW-BJ4-R-OR-WC2-PL.
2. LOW VOLTAGE CONTROL STATIONS (OVERRIDE SWITCHES) SHALL BE LABELED AS FOLLOWS OR AS DIRECTED BY OWNER:
 - 1 EXHIBIT
 - 2 MULTI-PURPOSE
 - 3 WINDOWS
 - 4 EXTERIOR
 - 5 MP/GFC/NK RM LTS
 - 6 ALL ON/OFF