



ADDITION, RENOVATIONS AND RECONSTRUCTIONS FOR
SPELLMAN MUSEUM
OF FORNEY HISTORY
200 S. BOIS D'ARC STREET - FORNEY, TEXAS 75126

FLOOR PLAN -
POWER & SIGNAL

AUGUST 21, 2012

E1.2

OF 5

ELECTRICAL POWER AND SIGNAL NOTES INDICATED BY SYMBOL: (#)

- 1 ALL RECEPTACLES SHALL BE INSTALLED NO LESS THAN 18" A.F.F. TO ACCOMMODATE A.D.A. REQUIREMENTS, UNLESS NOTED OTHERWISE.
- 2 ALL RECEPTACLES NOTED AS (#) SHALL BE INSTALLED ABOVE A COUNTER OR WORK SURFACE. THE MOUNTING HEIGHT SHALL BE VERIFIED AND COORDINATED WITH ARCHITECTURAL DETAILS.
- 3 ALL RECEPTACLES WITHIN 6'-0" OF A SINK OR LAVATORY SHALL BE "G.F.I." PROTECTED. NO EXCEPTIONS.
- 4 TELEPHONE, DATA, AND SIGNAL OUTLETS SHALL BE INSTALLED AT NO LESS THAN 18" A.F.F. TO ACCOMMODATE A.D.A. REQUIREMENTS, UNLESS NOTED OTHERWISE.
- 5 THE MOUNTING HEIGHT OF TELEPHONE, DATA, AND SIGNAL OUTLETS ABOVE COUNTER OR WORK SURFACES SHALL BE VERIFIED AND COORDINATED WITH ARCHITECTURAL DETAILS.
- 6 ALL TELEPHONE, DATA, AND SIGNAL OUTLETS (UNLESS NOTED OTHERWISE) SHALL INCLUDE A PLASTER RING AND PULL STRING. FINAL TELEPHONE, DATA, OR SIGNAL WIRING SHALL BE INSTALLED IN A SEPARATE CONTRACT.
- 7 CIRCUIT AND SWITCH EXHAUST FAN WITH LIGHTS.
- 8 DISCONNECT SWITCHES FOR MECHANICAL EQUIPMENT SHALL NOT BE INSTALLED ON MOVING PARTS, REMOVABLE ACCESS PANELS, OR ON THE EQUIPMENT NAMEPLATE. ALL EXTERIOR DISCONNECT SWITCHES AND CONTROL DEVICES SHALL BE WEATHERPROOF.
- 9 MULTI-OUTLET ASSEMBLY SHOWN ON EAST WALL OF EXHIBIT AREA, LOBBY EAST WALL, AND WEST WALL OF MULTI-PURPOSE ROOM SHALL BE WIREMOLD SERIES 3000 WITH DUPLEX OUTLETS INSTALLED ON 4'-0" CENTERS. VERIFY MOUNTING HEIGHT WITH OWNER. VERIFY COLOR OF WIREWAY AND RECEPTACLES WITH OWNER. WIRE MULTI-OUTLET ASSEMBLY SUCH THAT ALTERNATE DEVICES SHALL BE WIRED TO SWITCHED CIRCUIT. REFER TO LIGHTING CONTROLS SCHEDULE.
- 10 QUAD RECEPTACLES ON WEST WALL OF EXHIBIT HALL SHALL BE LOCATED ON 6'-0" CENTERS. VERIFY MOUNTING HEIGHT WITH OWNER.
- 11 SURFACE MOUNTED QUAD OUTLETS ON NORTH WALL OF EXHIBIT AREA AND EAST WALL MULTI-PURPOSE ROOM SHALL BE LOCATED ON 6'-0" CENTERS.
- 12 WHERE NOTED, FLUSH MOUNTED QUAD OUTLETS ON GYPBOARD WALLS SHALL BE LOCATED ON 6'-0" CENTERS.
- 13 CONTRACTOR SHALL VERIFY MANUFACTURER'S MCA AND MOCF FOR EXISTING HVAC EQUIPMENT AND SHALL PROVIDE APPROPRIATELY SIZED FUSED DISCONNECT SWITCH.
- 14 PROVIDE MATCHING CORD AND PLUG CONNECTION FOR DISPOSER.
- 15 WHERE NOTED, RECEPTACLES SHALL BE INSTALLED IN BULKHEAD BELOW GLASS.
- 16 REFER TO ARCHITECTURAL DRAWINGS FOR WALL MATERIALS AND FINISHES.
- 17 WHERE POSSIBLE ALL CONDUITS AND JUNCTION BOXES SHALL BE CONCEALED. WHERE NECESSARY TO INSTALL EXPOSED CONDUITS AND JUNCTION BOXES, CONTRACTOR SHALL INSTALL WORK IN A NEAT MANNER WITH CONSIDERATION TO VISIBILITY ON FINISHED SURFACES.
- 18 TELEPHONE BACKBOARD, 4'x8'x3/4" FIRE RESISTANT PLYWOOD, PAINTED TO MATCH WALL FINISH.
- 19 QUAD RECEPTACLES IN EXHIBIT AREA, LOBBY AND MULTI-PURPOSE ROOM SHALL BE WIRED SUCH THAT ONE HALF OF OUTLETS ARE ON SWITCHED CIRCUIT. REFER TO LIGHTING CONTROL SCHEDULE. SWITCHED OUTLETS SHALL BE DIFFERENT COLOR THAN NON-SWITCHED OUTLETS (I.E., NON-SWITCHED IVORY/WHITE, SWITCHED GRAY/BROWN). VERIFY DEVICE COLOR WITH OWNER.
- 20 WHERE INDICATED RECEPTACLE SHALL BE CONTROLLED VIA LIGHTING CONTROL SYSTEM. REFER TO CONTROL SCHEDULE.

